

## Application for Connecting to Municipal Water

County of Annapolis Office Locations & Hours of Operation					
752 St. George Street, Annapolis Roy PO Box 100 Annapolis Royal, NS BOS Tel: 902-532-2331 (Fax) 902-532-209 Open 8:30-4:30, Monday to Friday	1A0				
Office Use Only	System:	System:			
SAP:	AAN:	AAN: PID:			
Name of Registered Property Owner (Please Print)					
Name:	Phone:				
Location of Connection (Civic A	Cell:				
Mailing Address of Property Ow	Postal Code:				
Contractor Information					
Company Name:			Phon	Phone:	
Mailing Address:	Cell:				
Contact Name:			Posta	I Code:	
Comments:					
Description of Service					
No. of Connections Purpose of Lateral Office Use Only					
on Property	(check all that apply)	Comments	,, <b>,</b>	Depth to Pipe	
Existing					
After work complete	Single Dwelling			Distance from fixed point	
Service to be Installed				(give description)	
(check all that apply)	Duplex/Semi-Detached Apartment (no. of units)				
New	School (no. of units)			Meter #	
Sprinkler Service: Yes No	Nursing Home/Special Care			Initial Reading	
Size of Pipe	(no. of beds) Restaurant (seating capacity)	Inspected by			
Type of Pipe	Bar/Lounge (seating capacity)	Date Meter Size			
	Campground (no. of sites)	Date		Meter Type	
	Office (no. of employees) Other				
Connection Date:		Connection Fee		Paid	
				·N/A	
<u>Attach location plan or sketch lot</u> ; show building footprints, location of water main Water			ax Office		
Indicate North					
با لير			Application Check List		
Please Initial and Date					
			Engineering       Date:         Public Works       Date:		
	Finance Date:				
	Planning Date:				
Authorization					
I hereby declare this information to be true, accurate and complete to the best of my knowledge and request connection to the municipal water system. <b>PLEASE NOTE: Application not valid unless page 2 is signed.</b>					
Signature of Applicant	Print Name		Da	ite	

### WATER SERVICE CONNECTION FEES, NOTICE OF INSPECTION REQUIREMENTS AND SPECIFICATION DETAILS

This application is for the approval of a water connection to the Municipal Water System. Municipal Water Systems are deemed to terminate at the Curb Stop (Buried Service Valve) on the Water Service Pipe. Not all existing lots have water service lateral pipes installed to them. The customer is advised to confirm the presence of a lateral pipe by contacting Municipal Operations at 902-532-1445.

The Nova Scotia Utility Review Board (NSURB) Orders require that persons connecting to the water systems comply with technical specifications. The NSURB Orders require that the Municipality inspect water service pipe and fitting installations. The Bylaws require that the installer provide the Municipality sufficient notice to enable the Municipal Inspector to carry out the Municipal inspection.

# THE MUNICIPALITY'S FEES, NOTICE OF INSPECTION REQUIREMENTS, AND SPECIFICATION DETAILS ARE OUTLINED IN THE FOLLOWING:

#### FEES:

The Municipality charges a fee of \$50.00 for the connection to a water service.

The Property Owner is required to pay fees upon application submission, unless the requirement is waived in writing by the Municipality. The Property Owner is required to supply and install all pipes and fittings for the water service connection.

#### **NOTICE OF INSPECTION REQUIREMENTS:**

The customer is required to have the Municipality inspect the work **before it is backfilled**. **If these requirements are not followed, the customer will be fully responsible for any possible damage or cost relating to a faulty water connection and may be asked to uncover the connection for a proper inspection.** The Customer is to notify the Municipality and allow approximately two (2) working days' notice that an inspection is required. To book an inspection <u>please call</u> Municipal Operations at 902-532-1445, between the hours of 8:30 am and 4:30 pm, Monday to Friday, except for Public Holidays.

#### **SPECIFICATION DETAILS:**

- Water pipe shall be either Copper Tubing, conforming to ASTM B88, Type K annealed and with a pressure rating of 150 psi (1035 kPa), or Polyethylene Tubing, conforming to CAN/CSA B137.1-M Type PE, Series 160
- Water service pipe shall have a minimum diameter of <sup>3</sup>/<sub>4</sub> inches (20 mm)
- Water pipe shall be buried a minimum depth of 4.5 feet (1.4 meters)
- Water pipe shall be joined, bedded, and backfilled in accordance with the Manufacturer's instructions

I hereby agree to comply with the Nova Scotia Utility Review Board Orders as well as the specifications for installation of water lateral(s) on private property.

Print Name

Signature

Date