

**CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY**  
**PO Box 100**  
**Annapolis Royal, NS B0S1A0**  
**(902) 532-3141**

**ATTENTION TO: James Jenner**

**PROJECT: Health Canada Lead**

**AGAT WORK ORDER: 21X789410**

**WATER ANALYSIS REVIEWED BY: Ashley Dussault, Report Writer**

**DATE REPORTED: Aug 30, 2021**

**PAGES (INCLUDING COVER): 10**

**VERSION\*: 1**

Should you require any information regarding this analysis please contact your client services representative at (902) 468-8718

\*Notes

*Disclaimer:*

- *All work conducted herein has been done using accepted standard protocols, and generally accepted practices and methods. AGAT test methods may incorporate modifications from the specified reference methods to improve performance.*
- *All samples will be disposed of within 30 days after receipt unless a Long Term Storage Agreement is signed and returned. Some specialty analysis may be exempt, please contact your Client Project Manager for details.*
- *AGAT's liability in connection with any delay, performance or non-performance of these services is only to the Client and does not extend to any other third party. Unless expressly agreed otherwise in writing, AGAT's liability is limited to the actual cost of the specific analysis or analyses included in the services.*
- *This Certificate shall not be reproduced except in full, without the written approval of the laboratory.*
- *The test results reported herewith relate only to the samples as received by the laboratory.*
- *Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to, warranties of merchantability, fitness for a particular purpose, or non-infringement. AGAT assumes no responsibility for any errors or omissions in the guidelines contained in this document.*
- *All reportable information as specified by ISO/IEC 17025:2017 is available from AGAT Laboratories upon request.*



## Certificate of Analysis

AGAT WORK ORDER: 21X789410

PROJECT: Health Canada Lead

11 Morris Drive, Unit 122  
 Dartmouth, Nova Scotia  
 CANADA B3B 1M2  
 TEL (902)468-8718  
 FAX (902)468-8924  
<http://www.agatlabs.com>

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY

ATTENTION TO: James Jenner

SAMPLING SITE:

SAMPLED BY:

### Health Canada Lead Sampling - Drinking Water

DATE RECEIVED: 2021-08-18

DATE REPORTED: 2021-08-30

				SAMPLE DESCRIPTION: 61 Church St		154 Church St		63 Church St		419 Granville St		4187 Charlton Corner		165 Jeffery St		54 Rectory St		183 Centennial Dr	
				SAMPLE TYPE: Water		Water		Water		Water		Water		Water		Water		Water	
				DATE SAMPLED: 2021-08-17 08:14		2021-08-17 06:45		2021-08-17 06:20		2021-08-17 07:02		2021-08-17 06:10		2021-08-17 07:40		2021-08-17 06:30		2021-08-17 06:00	
Parameter	Unit	G / S	RDL	2864987	2865051	2865052	2865053	2865054	2865055	2865056	2865057								
Total Lead - Health Canada	ug/L	5	0.5	1.1	<0.5	<0.5	<0.5	<0.5	0.9	<0.5	<0.5								
				SAMPLE DESCRIPTION: 25 Cromwell Ct		16 Bay Rd													
				SAMPLE TYPE: Water		Water													
				DATE SAMPLED: 2021-08-17 07:10		2021-08-17 07:15													
Parameter	Unit	G / S	RDL	2865058	2865059														
Total Lead - Health Canada	ug/L	5	0.5	<0.5	<0.5														

**Comments:** RDL - Reported Detection Limit; G / S - Guideline / Standard: Refers to Canadian Drinking Water Quality - updated 2021-03  
 Guideline values are for general reference only. The guidelines provided may or may not be relevant for the intended use. Refer directly to the applicable standard for regulatory interpretation.  
 Analysis performed at AGAT Halifax (unless marked by \*)

**Certified By:**



## Certificate of Analysis

AGAT WORK ORDER: 21X789410

PROJECT: Health Canada Lead

11 Morris Drive, Unit 122  
 Dartmouth, Nova Scotia  
 CANADA B3B 1M2  
 TEL (902)468-8718  
 FAX (902)468-8924  
<http://www.agatlabs.com>

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY

ATTENTION TO: James Jenner

SAMPLING SITE:

SAMPLED BY:

### Standard Water Analysis + Total Metals

DATE RECEIVED: 2021-08-18

DATE REPORTED: 2021-08-30

Parameter	Unit	G / S	RDL	Bridgetown	Bridgetown
				Treated	Raw
				Water	Water
				2021-08-17 06:45	2021-08-17 06:40
				2865063	2865069
pH		7.0-10.5		7.92	7.79
Reactive Silica as SiO2	mg/L		0.5	18.7	19.0
Chloride	mg/L	250 AO	1	12	10
Fluoride	mg/L	1.5	0.12	0.17	0.13
Sulphate	mg/L	500 AO	2	23	24
Alkalinity	mg/L		5	112	111
True Color	TCU	15 AO	5.00	<5.00	<5.00
Turbidity	NTU	1.0	0.5	1.2	0.6
Electrical Conductivity	umho/cm		1	336	326
Nitrate + Nitrite as N	mg/L		0.05	0.69	0.85
Nitrate as N	mg/L	10	0.05	0.69	0.85
Nitrite as N	mg/L	1.0	0.05	<0.05	<0.05
Ammonia as N	mg/L		0.03	<0.03	<0.03
Total Organic Carbon	mg/L		0.5	<0.5	<0.5
Ortho-Phosphate as P	mg/L		0.01	0.05	0.04
Total Sodium	mg/L	200 AO	0.1	8.9	8.1
Total Potassium	mg/L		0.1	0.8	0.8
Total Calcium	mg/L		0.1	57.3	46.2
Total Magnesium	mg/L		0.1	2.2	2.2
Bicarb. Alkalinity (as CaCO3)	mg/L		5	112	111
Carb. Alkalinity (as CaCO3)	mg/L		10	<10	<10
Hydroxide	mg/L		5	<5	<5
Calculated TDS	mg/L	500 AO	1	174	162
Hardness	mg/L			152	124
Langelier Index (@20C)	NA			0.12	-0.11
Langelier Index (@ 4C)	NA			-0.20	-0.43
Saturation pH (@ 20C)	NA			7.80	7.90
Saturation pH (@ 4C)	NA			8.12	8.22

**Certified By:**



## Certificate of Analysis

AGAT WORK ORDER: 21X789410

PROJECT: Health Canada Lead

11 Morris Drive, Unit 122  
 Dartmouth, Nova Scotia  
 CANADA B3B 1M2  
 TEL (902)468-8718  
 FAX (902)468-8924  
<http://www.agatlabs.com>

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY

ATTENTION TO: James Jenner

SAMPLING SITE:

SAMPLED BY:

### Standard Water Analysis + Total Metals

DATE RECEIVED: 2021-08-18

DATE REPORTED: 2021-08-30

Parameter	Unit	G / S	RDL	Bridgetown	Bridgetown
				Treated	Raw
				Water	Water
				2021-08-17	2021-08-17
				06:45	06:40
				2865063	2865069
Anion Sum	me/L			3.11	3.06
Cation sum	me/L			3.45	2.86
% Difference/ Ion Balance	%			5.3	3.4
Total Aluminum	ug/L	2900, 100	5	<5	<5
Total Antimony	ug/L	6	2	<2	<2
Total Arsenic	ug/L	10	2	2	2
Total Barium	ug/L	2000	5	205	202
Total Beryllium	ug/L		2	<2	<2
Total Bismuth	ug/L		2	<2	<2
Total Boron	ug/L	5000	5	9	9
Total Cadmium	ug/L	7	0.09	<0.09	<0.09
Total Chromium	ug/L	50	1	<1	<1
Total Cobalt	ug/L		1	<1	<1
Total Copper	ug/L	2000, 1000	1	11	<1
Total Iron	ug/L	300 AO	50	<50	<50
Total Lead	ug/L	5	0.5	<0.5	<0.5
Total Manganese	ug/L	120, 20 AO	2	<2	<2
Total Molybdenum	ug/L		2	<2	<2
Total Nickel	ug/L		2	3	<2
Total Phosphorous	mg/L		0.02	0.05	0.05
Total Selenium	ug/L	50	1	<1	<1
Total Silver	ug/L		0.1	<0.1	<0.1
Total Strontium	ug/L	7000	5	236	230
Total Thallium	ug/L		0.1	<0.1	<0.1
Total Tin	ug/L		2	<2	<2
Total Titanium	ug/L		2	<2	<2
Total Uranium	ug/L	20	0.2	6.8	7.0
Total Vanadium	ug/L		2	4	4

**Certified By:**



## Certificate of Analysis

AGAT WORK ORDER: 21X789410

PROJECT: Health Canada Lead

11 Morris Drive, Unit 122  
Dartmouth, Nova Scotia  
CANADA B3B 1M2  
TEL (902)468-8718  
FAX (902)468-8924  
<http://www.agatlabs.com>

CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY

ATTENTION TO: James Jenner

SAMPLING SITE:

SAMPLED BY:

### Standard Water Analysis + Total Metals

DATE RECEIVED: 2021-08-18

DATE REPORTED: 2021-08-30

Parameter	Unit	G / S	RDL	Bridgetown	Bridgetown
				Treated	Raw
SAMPLE DESCRIPTION:				Water	Water
SAMPLE TYPE:				Water	Water
DATE SAMPLED:				2021-08-17 06:45	2021-08-17 06:40
				<b>2865063</b>	<b>2865069</b>
Total Zinc	ug/L	5000 AO	5	<5	<5

**Comments:** RDL - Reported Detection Limit; G / S - Guideline / Standard: Refers to Canadian Drinking Water Quality - updated 2021-03  
Guideline values are for general reference only. The guidelines provided may or may not be relevant for the intended use. Refer directly to the applicable standard for regulatory interpretation.

**2865063-2865069** % Difference / Ion Balance, Hardness, Langelier Index, Nitrate + Nitrite, Hydroxide and Saturation pH are calculated parameters. The calculated parameters are non-accredited. The component parameters of the calculations are accredited.

Analysis performed at AGAT Halifax (unless marked by \*)

**Certified By:**

## Quality Assurance

**CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY**
**AGAT WORK ORDER: 21X789410**
**PROJECT: Health Canada Lead**
**ATTENTION TO: James Jenner**
**SAMPLING SITE:**
**SAMPLED BY:**

Water Analysis															
RPT Date: Aug 30, 2021			DUPLICATE				Method Blank	REFERENCE MATERIAL			METHOD BLANK SPIKE			MATRIX SPIKE	
PARAMETER	Batch	Sample Id	Dup #1	Dup #2	RPD	Measured Value		Acceptable Limits		Recovery	Acceptable Limits		Recovery	Acceptable Limits	
								Lower	Upper		Lower	Upper		Lower	Upper

**Health Canada Lead Sampling - Drinking Water**

Total Lead - Health Canada	2882864	<0.5	<0.5	NA	< 0.5	101%	80%	120%	106%	80%	120%	96%	70%	130%
----------------------------	---------	------	------	----	-------	------	-----	------	------	-----	------	-----	-----	------

Comments: If RPD value is NA, the results of the duplicates are less than 5x the RDL and the RPD will not be calculated.

**Standard Water Analysis + Total Metals**

pH	2865063	2865063	7.92	7.83	1.1%	<	NA	80%	120%	NA			NA		
Reactive Silica as SiO2	2860511		15.7	13.0	18.8%	< 0.5	100%	80%	120%	100%	80%	120%	109%	80%	120%
Chloride	2865817		326	365	11.3%	< 1	86%	80%	120%	NA	80%	120%	NA	70%	130%
Fluoride	2865817		0.43	0.55	NA	< 0.12	91%	80%	120%	NA	80%	120%	95%	70%	130%
Sulphate	2865817		28	33	15.9%	< 2	99%	80%	120%	NA	80%	120%	NA	70%	130%
Alkalinity	2865063	2865063	112	111	1.1%	< 5	87%	80%	120%	NA			NA		
True Color	2859711		8.24	9.66	NA	< 5	107%	80%	120%	92%	80%	120%	NA		
Turbidity	2866465		1.7	1.9	NA	< 0.5	93%	80%	120%	NA			NA		
Electrical Conductivity	2865063	2865063	336	332	1.2%	< 1	104%	90%	110%	NA			NA		
Nitrate as N	2865817		<0.05	<0.05	NA	< 0.05	80%	80%	120%	NA	80%	120%	89%	70%	130%
Nitrite as N	2865817		<0.05	0.11	NA	< 0.05	86%	80%	120%	NA	80%	120%	87%	70%	130%
Ammonia as N	2871162		<0.03	<0.03	NA	< 0.03	98%	80%	120%	91%	80%	120%	122%	70%	130%
Total Organic Carbon	2865063	2865063	<0.5	<0.5	NA	<0.5	96%	80%	120%	NA	80%	120%	80%	80%	120%
Ortho-Phosphate as P	2859711		0.02	0.02	NA	< 0.01	101%	80%	120%	101%	80%	120%	110%	80%	120%
Total Sodium	2869402		32.6	33.1	1.5%	< 0.1	100%	80%	120%	98%	80%	120%	NA	70%	130%
Total Potassium	2869402		2.4	2.6	6.2%	< 0.1	111%	80%	120%	109%	80%	120%	NA	70%	130%
Total Calcium	2869402		29.0	27.8	4.3%	< 0.1	108%	80%	120%	106%	80%	120%	NA	70%	130%
Total Magnesium	2869402		4.1	4.3	4.0%	< 0.1	100%	80%	120%	95%	80%	120%	NA	70%	130%
Bicarb. Alkalinity (as CaCO3)	2865063	2865063	112	111	1.1%	< 5	NA	80%	120%	NA			NA		
Carb. Alkalinity (as CaCO3)	2865063	2865063	<10	<10	NA	< 10	NA	80%	120%	NA			NA		
Hydroxide	2865063	2865063	<5	<5	NA	< 5	NA	80%	120%	NA			NA		
Total Aluminum	2869402		16	16	NA	< 5	113%	80%	120%	108%	80%	120%	103%	70%	130%
Total Antimony	2869402		<2	<2	NA	< 2	91%	80%	120%	103%	80%	120%	94%	70%	130%
Total Arsenic	2869402		<2	<2	NA	< 2	99%	80%	120%	105%	80%	120%	96%	70%	130%
Total Barium	2869402		88	94	6.9%	< 5	99%	80%	120%	103%	80%	120%	NA	70%	130%
Total Beryllium	2869402		<2	<2	NA	< 2	114%	80%	120%	111%	80%	120%	94%	70%	130%
Total Bismuth	2869402		<2	<2	NA	< 2	103%	80%	120%	109%	80%	120%	92%	70%	130%
Total Boron	2869402		9	10	NA	< 5	96%	80%	120%	93%	80%	120%	83%	70%	130%
Total Cadmium	2869402		<0.09	<0.09	NA	< 0.09	97%	80%	120%	100%	80%	120%	90%	70%	130%
Total Chromium	2869402		<1	<1	NA	< 1	96%	80%	120%	99%	80%	120%	103%	70%	130%
Total Cobalt	2869402		<1	<1	NA	< 1	98%	80%	120%	100%	80%	120%	105%	70%	130%
Total Copper	2869402		4	4	NA	< 1	99%	80%	120%	102%	80%	120%	102%	70%	130%
Total Iron	2869402		66	54	NA	< 50	97%	80%	120%	97%	80%	120%	104%	70%	130%
Total Lead	2869402		<0.5	<0.5	NA	< 0.5	101%	80%	120%	105%	80%	120%	93%	70%	130%
Total Manganese	2869402		6	6	NA	< 2	97%	80%	120%	99%	80%	120%	104%	70%	130%

## Quality Assurance

**CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY**
**AGAT WORK ORDER: 21X789410**
**PROJECT: Health Canada Lead**
**ATTENTION TO: James Jenner**
**SAMPLING SITE:**
**SAMPLED BY:**

### Water Analysis (Continued)

RPT Date: Aug 30, 2021			DUPLICATE				Method Blank	REFERENCE MATERIAL			METHOD BLANK SPIKE			MATRIX SPIKE		
PARAMETER	Batch	Sample Id	Dup #1	Dup #2	RPD	Measured Value		Acceptable Limits		Recovery	Acceptable Limits		Recovery	Acceptable Limits		
								Lower	Upper		Lower	Upper		Lower	Upper	
Total Molybdenum	2869402		<2	<2	NA	< 2	94%	80%	120%	97%	80%	120%	101%	70%	130%	
Total Nickel	2869402		<2	<2	NA	< 2	98%	80%	120%	99%	80%	120%	103%	70%	130%	
Total Phosphorous	2869402		<0.02	<0.02	NA	< 0.02	102%	80%	120%	87%	80%	120%	84%	70%	130%	
Total Selenium	2869402		1	1	NA	< 1	93%	80%	120%	104%	80%	120%	90%	70%	130%	
Total Silver	2869402		<0.1	<0.1	NA	< 0.1	96%	80%	120%	97%	80%	120%	87%	70%	130%	
Total Strontium	2869402		157	155	1.2%	< 5	89%	80%	120%	87%	80%	120%	NA	70%	130%	
Total Thallium	2869402		<0.1	<0.1	NA	< 0.1	99%	80%	120%	104%	80%	120%	93%	70%	130%	
Total Tin	2869402		<2	<2	NA	< 2	99%	80%	120%	99%	80%	120%	97%	70%	130%	
Total Titanium	2869402		<2	<2	NA	< 2	96%	80%	120%	92%	80%	120%	96%	70%	130%	
Total Uranium	2869402		<0.2	<0.2	NA	< 0.2	98%	80%	120%	102%	80%	120%	97%	70%	130%	
Total Vanadium	2869402		<2	<2	NA	< 2	96%	80%	120%	94%	80%	120%	105%	70%	130%	
Total Zinc	2869402		5	5	NA	< 5	98%	80%	120%	100%	80%	120%	96%	70%	130%	

Comments: If RPD value is NA, the results of the duplicates are less than 5x the RDL and the RPD will not be calculated.

**Certified By:**


## Method Summary

**CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY**
**AGAT WORK ORDER: 21X789410**
**PROJECT: Health Canada Lead**
**ATTENTION TO: James Jenner**
**SAMPLING SITE:**
**SAMPLED BY:**

PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE
<b>Water Analysis</b>			
Total Lead - Health Canada	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
pH	INOR-121-6001	SM 4500 H+B	PC TITRATE
Reactive Silica as SiO <sub>2</sub>	INOR-121-6027	SM 4500-SiO <sub>2</sub> F	COLORIMETER
Chloride	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH
Fluoride	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH
Sulphate	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH
Alkalinity	INOR-121-6001	SM 2320 B	
True Color	INOR-121-6008	SM 2120 B	LACHAT FIA
Turbidity	INOR-121-6022	SM 2130 B	NEPHELOMETER
Electrical Conductivity	INOR-121-6001	SM 2510 B	PC TITRATE
Nitrate + Nitrite as N	INORG-121-6005	SM 4110 B	CALCULATION
Nitrate as N	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH
Nitrite as N	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH
Ammonia as N	INOR-121-6047	SM 4500-NH <sub>3</sub> H	COLORIMETER
Total Organic Carbon	INOR-121-6026	SM 5310 B	TOC ANALYZER
Ortho-Phosphate as P	INOR-121-6012	SM 4500-P G	COLORIMETER
Total Sodium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Potassium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Calcium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Magnesium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Bicarb. Alkalinity (as CaCO <sub>3</sub> )	INORG-121-6001	SM 2320 B	PC TITRATE
Carb. Alkalinity (as CaCO <sub>3</sub> )	INORG-121-6001	SM 2320 B	PC TITRATE
Hydroxide	INORG-121-6001	SM 2320 B	PC-TITRATE
Calculated TDS	CALCULATION	SM 1030E	CALCULATION
Hardness	CALCULATION	SM 2340B	CALCULATION
Langelier Index (@20C)	CALCULATION	CALCULATION	CALCULATION
Langelier Index (@ 4C)	CALCULATION	CALCULATION	CALCULATION
Saturation pH (@ 20C)	CALCULATION	CALCULATION	CALCULATION
Saturation pH (@ 4C)	CALCULATION	CALCULATION	CALCULATION
Anion Sum	CALCULATION	SM 1030E	CALCULATION
Cation sum	CALCULATION	SM 1030E	CALCULATION
% Difference/ Ion Balance	CALCULATION	SM 1030E	CALCULATION
Total Aluminum	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Antimony	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Total Arsenic	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Barium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Beryllium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Bismuth	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Boron	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS



## Method Summary

**CLIENT NAME: MUNICIPALITY OF ANNAPOLIS COUNTY**
**AGAT WORK ORDER: 21X789410**
**PROJECT: Health Canada Lead**
**ATTENTION TO: James Jenner**
**SAMPLING SITE:**
**SAMPLED BY:**

PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE
Total Cadmium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Chromium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Cobalt	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Copper	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Iron	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Lead	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Manganese	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Molybdenum	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Nickel	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Phosphorous	MET-121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Selenium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Silver	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Strontium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Thallium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Tin	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Titanium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Uranium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Vanadium	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS
Total Zinc	MET121-6104 & MET-121-6105	modified from SM 3125/SM 3030 B/SM 3030 D	ICP-MS



# AGAT Laboratories

Unit 122 • 11 Morris Drive  
Dartmouth, NS  
B3B 1M2  
webearth.agatlabs.com • www.agatlabs.com

**Laboratory Use Only**

Arrival Condition:  Good  Poor (see notes)

Arrival Temperature: 11.4, 12.1, 10

Hold Time: 13 AUG 18 9:49AM

AGAT Job Number: 21X789410

Notes:

## Chain of Custody Record

P: 902.468.8718 • F: 902.468.8924

**Report Information**

Company: Mun of the County of Annapolis

Contact: James Jenner

Address: PO BOX 100 St George St  
Annapolis Royal B0S 1A0

Phone: 902-526-0566 Fax: 902-532-2096

Client Project #: Health Canada Lead

AGAT Quotation: \_\_\_\_\_

Please Note: If quotation number is not provided client will be billed full price for analysis.

**Report Information** (Please print):

1. Name: James Jenner  
Email: jjenner@annapoliscounty.ca

2. Name: Charles Grant  
Email: cgrant@annapoliscounty.ca

**Report Format**

Single Sample per page

Multiple Samples per page

Excel Format Included

Export

**Turnaround Time Required (TAT)**

Regular TAT  5 to 7 working days

Rush TAT  Same day  1 day  
 2 days  3 days

Date Required: \_\_\_\_\_

**Invoice To** Same Yes  / No

Company: \_\_\_\_\_

Contact: Amanda Lewis

Address: \_\_\_\_\_

Phone: \_\_\_\_\_ Fax: \_\_\_\_\_

PO/Credit Card#: \_\_\_\_\_

**Regulatory Requirements** (Check):

List Guidelines on Report  Do not list Guidelines on Report

PIRI

Tier 1  Res  Pot  Coarse  
 Tier 2  Com  N/Pot  Fine  
 Gas  Fuel  Lube

CCME  CDWQ  
 Industrial  NSEQS-Cont Sites  
 Commercial  HRM 101  
 Res/Park  Storm Water  
 Agricultural  Waste Water  
 FWAL  
 Sediment  Other \_\_\_\_\_

Drinking Water Sample:  Yes  No Salt Water Sample  Yes  No

Reg. No.: \_\_\_\_\_

Sample Identification	Date/Time Sampled	Sample Matrix	# Containers	Comments - Site/Sample Info. Sample Containment	Field Filtered/Preserved	Standard Water Analysis	Metals: <input checked="" type="checkbox"/> Total <input type="checkbox"/> Diss <input type="checkbox"/> Available	Mercury	<input type="checkbox"/> BOD <input type="checkbox"/> CBOD	pH	<input type="checkbox"/> TSS <input type="checkbox"/> TDS <input type="checkbox"/> VSS	TKN	Total Phosphorus	Phenols	Tier 1: TPH/BTEX (PIR) <input type="checkbox"/> low level	Tier 2: TPH/BTEX Fractionation	CCME-CWS TPH/BTEX	VOC	THM	HAA	PAH	PCB	TC + EC <input type="checkbox"/> P/A <input type="checkbox"/> MPN <input type="checkbox"/> MF	<input type="checkbox"/> HPC <input type="checkbox"/> Pseudomonas	Fecal Coliform <input type="checkbox"/> MPN <input type="checkbox"/> MF	Other: Health Canada Lead	Other:	Hazardous (Y/N)
61 Church St	Aug 17/21 <u>8:14am</u>		1																							<input checked="" type="checkbox"/>		
154 Church St	Aug 17/21 <u>6:45am</u>		1																								<input checked="" type="checkbox"/>	
63 Church St	Aug 17/21 <u>6:24am</u>		1																								<input checked="" type="checkbox"/>	
419 Granville St	Aug 17/21 <u>7:02am</u>		1																								<input checked="" type="checkbox"/>	
4187 Charlton Corner	Aug 17/21 <u>6:10am</u>		1																								<input checked="" type="checkbox"/>	
165 Jeffery St	Aug 17/21 <u>7:40am</u>		1																								<input checked="" type="checkbox"/>	
54 Rectory St	Aug 17/21 <u>6:36am</u>		1																								<input checked="" type="checkbox"/>	
183 Centennial Dr	Aug 17/21 <u>6:00am</u>		1																								<input checked="" type="checkbox"/>	
25 Cromwell Ct	Aug 17/21 <u>7:10am</u>		1																								<input checked="" type="checkbox"/>	
16 Bay Rd	Aug 17/21 <u>7:13am</u>		1																								<input checked="" type="checkbox"/>	
Bridgetown Treated	Aug 17/21 <u>6:45am</u>		3																								<input checked="" type="checkbox"/>	
Bridgetown Raw	Aug 17/21 <u>6:40am</u>		3																								<input checked="" type="checkbox"/>	

Samples Relinquished By (Print Name): <u>Amy Brown</u>	Date/Time: <u>Aug 17/21</u>	Samples Received By (Print Name): <u>[Signature]</u>	Date/Time: _____	Pink Copy - Client	Page <input type="text"/> of <input type="text"/>
Samples Relinquished By (Sign): <u>[Signature]</u>	Date/Time: <u>9:00am</u>	Samples Received By (Sign): <u>[Signature]</u>	Date/Time: _____	Yellow Copy - AGAT	No:
				White Copy - AGAT	

Included ID: 133137-022

Date revised: May 5, 2020